



A P P R O V A L S ®

Certificate of Suitability

Addendum

Certificate No.: SAA210676

Date of Issue: 22 April 2021

Regulatory Definition: Non-Prescribed

Product Description: PV Grid Inverter

Additional Models	Trade Name	Rating/Marking
MIN 9000TL-X	GROWATT	Input: MPPT Voltage Range: 60-550Vdc, Max 600Vdc Max 13.5/13.5/27A Isc: 16.9/16.9/33.8A Output: 230Vac 50/60Hz Max 43A 9000W Rated current 39.1A Rated apparent power 9000VA Class I, IP66, -25°C to +60°C

R. A. Hill

For and on Behalf of
SAA Approvals Pty Ltd

This certificate is issued by SAA Approvals Pty Ltd in accordance with the SAA Approvals Electrical Product Safety Certification Scheme accredited by JAS-ANZ under AS/NZS ISO/IEC 17065 and RECS accreditation under the Queensland Government legislative requirements. SAA certifies the product nominated in this certificate complies with standard/s listed above in accordance with the schemes herein.

For SAA Contact Details and to verify this Certificate go to:

www.saaapprovals.com.au

JAS-ANZ



www.jas-anz.org/register



Issued: 22-06-21 210676/3a
Rating corrected