

Test Verification of Conformity


Verification Number: 181016129GZU-002

On the basis of the referenced test report(s), sample(s) tested of the below product have been found to comply with the standards harmonized with the directives listed on this verification at the time the tests were carried out. Other standards and Directives may be relevant to the product. This verification is part of the full test report(s) and should be read in conjunction with it <them>.

Once compliance with all product relevant **CE** mark directives are verified, including any relevant e.g. risk assessment and production control, the manufacturer may indicate compliance by signing a Declaration of Conformity themselves and applying the mark to products identical to the tested sample(s).

Applicant Name & Address:	Shenzhen Growatt New Energy Technology Co.,Ltd 1st East & 3rd Floor of Building A, Building B, Jiayu Industrial Park, #28, GuangHui Road, LongTeng Community, Shiyan Street, Baoan District, Shenzhen, P.R.China
Product Description:	PV Grid inverter
Models/Type References:	MIN 2500TL-X, MIN 3000TL-X, MIN 3600TL-X, MIN 4200TL-X, MIN 4600TL-X, MIN 5000TL-X, MIN 6000TL-X
Ratings & Principle Characteristics:	See Appendix
Brand Name(s):	Growatt
Standard(s)/Directive(s):	EN 61000-6-4:2007+A1:2011 EN 61000-6-2:2005 EMC Directive 2014/30/EU
Verification Issuing Office Name & Address:	Intertek Testing Services Shenzhen Ltd. Guangzhou Branch Block E, No.7-2 Guang Dong Software Science Park, Caipin Road, Guangzhou Science City, GETDD Guangzhou, China
Test Report Number(s):	181016129GZU-002

Additional information in Appendix.



Signature

Name: Strong Yao

Position: Manager

Date: 18 March 2019

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

APPENDIX: Test Verification of Conformity

This is an Appendix to Test Verification of Conformity Number: 181016129GZU-002

Ratings & Principle Characteristics:

Model	MIN 2500TL- X	MIN 3000TL- X	MIN 3600TL- X	MIN 4200TL- X
Max.PV voltage	500 d.c.V		550 d.c.V	
PV voltage range	80-500 d.c.V		80-550 d.c.V	
PV Isc	16 d.c.A*2			
Max.input current	12.5 d.c.A*2			
Max.output power	2500W	3000W	3600W	4200W
Max.apparent power	2500VA	3000VA	3600VA	4200VA
Nominal output voltage	230 a.c.V			
Max.output current	11.3 a.c.A	13.6 a.c.A	16 a.c.A	19 a.c.A
Nominal output Frequency	50/60Hz			
Power factor range	0.8Leading – 0.8 lagging			
Safety level	Class I			
Ingress Protection	IP 65			
Operation Ambient Temperature	-25°C - +60°C			

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

Model	MIN 4600TL-X	MIN 5000TL-X	MIN 6000TL-X
Max.PV voltage	550 d.c.V		
PV voltage range	80-550 d.c.V		
PV Isc	16 d.c.A*2		
Max.input current	12.5 d.c.A*2		
Max.output power	4600W	5000W	6000W
Max.apparent power	4600VA	5000VA	6000VA
Nominal output voltage	230 a.c.V		
Max.output current	20.9 a.c.A	22.7 a.c.A	27.2 a.c.A
Nominal output Frequency	50/60Hz		
Power factor range	0.8Leading – 0.8 lagging		
Safety level	Class I		
Ingress Protection	IP 65		
Operation Ambient Temperature	-25°C - +60°C		



Signature

Name: Strong Yao

Position: Manager

Date: 18 March 2019

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.